

CERTIFICATE OF APPROVAL

Authorised marking: TUV022504EA

This is to certify that TÜV Rheinland Australia Pty Ltd as accredited by JAS-ANZ in accordance with ISO/IEC Guide 65 has examined for compliance with certification standards, the electrical equipment described hereunder and authorises the certificate holder to affix the above mentioned mark to products of the same type; or the Regulatory Compliance Mark (RCM) provided that the requirements of all relevant parts of AS/NZS 4417 applicable to the article are fulfilled

CERTIFICATE HOLDER: Olex Australia Pty. Ltd.
55 Main Street
Lilydale VIC 3140

DESCRIPTION OF EQUIPMENT

Declared class: BUILDING WIRING CABLE

Product: Polymeric Insulated Electric Cable[®]

Trade Name / Manufacturer: Nexans Olex

Model Number: DNHP series; FNHP series; HNHP series.
(Model number details refer to CONTINUATION SHEET 1).


Ratings: 0.6/1kV, V-90 PVC insulated, 5V-90 PVC sheathed,
circular electric cable.

Standard: AS/NZS 5000.1:2005+A1

Issue Date: 19/02/2018

Expiry Date: 19/02/2023

Signed for and on behalf of TÜV Rheinland Australia Pty Ltd



Billy Chu



Acc. No. Z2870404AA
www.jas-anz.org/register

CERTIFICATE OF APPROVAL

Authorised marking: TUV022504EA

CONTINUATION SHEET 1

DESCRIPTION OF EQUIPMENT

Description of the cables:

DNHP05, 2C+E, 1.5mm²+E 1.5mm²;
DNHP07, 2C+E, 2.5mm²+E 2.5mm²;
DNHP09, 2C+E, 4mm²+E 2.5mm²;
DNHP11, 2C+E, 6mm²+E 2.5mm²;
DNHP13, 2C+E, 10mm²+E 4mm²;
DNHP15, 2C+E, 16mm²+E 6mm².


FNHP05, 3C+E, 1.5mm²+E 1.5mm²;
FNHP07, 3C+E, 2.5mm²+E 2.5mm²;
FNHP09, 3C+E, 4mm²+E 2.5mm²;
FNHP11, 3C+E, 6mm²+E 2.5mm²;
FNHP13, 3C+E, 10mm²+E 4mm²;
FNHP15, 3C+E, 16mm²+E 6mm².

HNHP05, 4C+E, 1.5mm²+E 1.5mm²;
HNHP07, 4C+E, 2.5mm²+E 2.5mm²;
HNHP09, 4C+E, 4mm²+E 2.5mm²;
HNHP11, 4C+E, 6mm²+E 2.5mm²;
HNHP13, 4C+E, 10mm²+E 4mm²;
HNHP15, 4C+E, 16mm²+ E 6mm².

Issue Date: 19/02/2018

Expiry Date: 19/02/2023

Signed for and on behalf of TÜV Rheinland Australia Pty Ltd



Billy Chu



Acc. No. Z2870404AA
www.jas-anz.org/register