

**Certificate Number:** AZ 69026235

Page: 0001



## CERTIFICATE OF APPROVAL

Authorised marking: TUV-026235-EA

TÜV Rheinland Australia Pty Ltd "Electrical Product Safety Certification (EPSC) Scheme", accredited by JAS-ANZ in accordance with ISO/IEC 17065, has issued this certificate under the Gas and Electricity (Consumer safety) Act 2017 as a declared Recognised External Approval Scheme (REAS). The electrical equipment described hereunder has been evaluated and found to be electrically safe at the time of certification. It is a requirement that all equipment supplied under this certificate shall be identical to the equipment as certified. The certificate holder shall place the above mentioned authorised marking on the product. The certificate holder may use the Regulatory Compliance Mark (RCM) provided all the requirements of AS/NZS 4417.1 & AS/NZS 4417.2 applicable to the article are fulfilled.

### CERTIFICATE HOLDER:

Olex Australia Pty. Ltd.  
55 Main Street  
Lilydale VIC 3140  
Australia

### DESCRIPTION OF EQUIPMENT

**Declared class:**

BUILDING WIRING CABLE

**Product:**

Polymeric Insulated Electric Cable

**Trade Name / Manufacturer:**

Nexans Olex

**Model Number:**

CNHP series; ENHP series; GNHP series.  
Refer to CONTINUATION SHEET 1 for further details

**Ratings:**

450/750V, V-90 insulated and 5V-90 sheathed cable.  
Remark: Alternative Authorised Marking "TUV021956EA" is applicable to above mentioned models.

**Standard:**

AS/NZS 5000.2:2006

**Issue Date:**

15/07/2022

**Expiry Date:**

15/07/2027

*Signed for and on behalf of TÜV Rheinland Australia Pty Ltd*

A handwritten signature in blue ink, appearing to read "Grant Li".

Grant Li



[www.jas-anz.org/register](http://www.jas-anz.org/register)

**Certificate Number:** AZ 69026235

Page: 0002



## CERTIFICATE OF APPROVAL

Authorised marking: TUV-026235-EA

CONTINUATION SHEET 1

DESCRIPTION OF EQUIPMENT

Model Number:

CNHP05 : 2 core +E, 1.5mm<sup>2</sup>

CNHP07 : 2 core +E, 2.5mm<sup>2</sup>

CNHP09 : 2 core +E, 4mm<sup>2</sup> + E 2.5mm<sup>2</sup>

CNHP11 : 2 core +E, 6mm<sup>2</sup> + E 2.5mm<sup>2</sup>

ENHP05 : 3 core +E, 1.5mm<sup>2</sup>

ENHP07 : 3 core +E, 2.5mm<sup>2</sup>

ENHP09 : 3 core +E, 4mm<sup>2</sup> + E 2.5mm<sup>2</sup>

ENHP011 : 3 core +E, 6mm<sup>2</sup> + E 2.5mm<sup>2</sup>

GNHP05 : 4 core +E, 1.5mm<sup>2</sup>

GNHP07 : 4 core +E, 2.5mm<sup>2</sup>

GNHP09 : 4 core +E, 4mm<sup>2</sup> + E 2.5mm<sup>2</sup>

GNHP11 : 4 core +E, 6mm<sup>2</sup> + E 2.5mm<sup>2</sup>

circular cable with Class 2 plain annealed copper conductors

Issue Date: 15/07/2022

Expiry Date: 15/07/2027

*Signed for and on behalf of TÜV Rheinland Australia Pty Ltd*

A handwritten signature in blue ink, appearing to read 'Grant Li', written over a horizontal line.

Grant Li



[www.jas-anz.org/register](http://www.jas-anz.org/register)